



Paroc Panel System:	Fire	Detail No.:	FI-I-901
Type:	Fire partitioning detail	Scale:	1:5
Subject:	Pipe penetration in partitioning wall Horizontal or vertical installation	Revision:	A
		Date: 10.06.2014	Revision Date: 05.05.2021
		Signature: KjN	Revision Signature: JeN

Notice: Principle Master Detail

Project specific changes on designer's responsibility

Copyright Paroc Panel System 2019-07-01


Wall classification:

The fire partitioning class according to the CE-approval for Paroc panel!

Classification must always be compared with national certificates and requirements!

Attention!

In fire partition walls/ceilings use always screws and rivets of steel!



Attention!!

All fasteners in partition walls of steel

Fasteners to the roof construction shall have enough capacity on both sides to resist loads from dead weight of panel + the pressure load reaction as catenary construction in case of fire.

When bigger pipes/ducts see detail FI-I-902